



Product Service

CERTIFICATE

No. Z2 068988 0105 Rev. 15

Holder of Certificate: **Jetion Solar (China) Co., Ltd.**

No. 1011, Zhencheng Rd.,
Shengang Industrial District
214443 Jiangyin
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061814810-15

Valid until: 2027-09-08

Date, 2022-09-09

(Zhulin Zhang)

CERTIFICATE

No. Z2 068988 0105 Rev. 15

Model(s):

JTxxxSAh, JTxxxSAh(1500), xxx=350-400, in steps of 5
 JTxxxSPh, JTxxxSPh(1500), xxx=295-335, in steps of 5
 JTxxxSGh, JTxxxSGh(1500), xxx=350-415, in steps of 5
 JTxxxSGh, JTxxxSGh(1500), xxx=430-460, in steps of 5
 JTxxxSHh, JTxxxSHh(1500), xxx=295-345, in steps of 5
 JTxxxSHh, JTxxxSHh(1500), xxx=355-380, in steps of 5
 JTxxxSGh(1500), xxx=520-550, in steps of 5
 JTxxxSFh(1500), xxx=480-505, in steps of 5
 JTxxxSHh(1500), xxx=435-460, in steps of 5
 JTxxxSEh(1500), xxx=390-415, in steps of 5
 JTxxxSVh(1500), xxx=435-465, in steps of 5
 JTxxxSFk, xxx=645-670, in steps of 5
 JTxxxSHk, xxx=585 to 605, in steps of 5
 JTxxxSWk, xxx=535 to 555, in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.
Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1000 V DC or 1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 EN 61215-1:2016
 EN 61215-1-1:2016
 EN 61215-2:2017
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06